

Modus Fixing Instructions


Please unpack your delivery carefully and inspect the radiator and contents – any damages or shortages must be notified to your supplier within 3 days of delivery of your goods.

Inside your accessories box you will have:

4-20 Sections	1 pair of Wall Ties/ 2 x Wall Brackets /	
	2 x Cast Feet /2 x Slip on Feet / 2 x	
	Floor Brackets	
21-40 Sections	2 pairs of Wall Ties/ 3 x Wall Brackets / 3 x Cast Feet /	
	3 x Slip on Feet / 3 x Floor Brackets	
41+ Sections	2 Pairs of Wall Ties/ 4 x Wall Brackets / 4 x Cast Feet /	
	4 x Slip on Feet / 4 x Floor Brackets	

TECHNICAL SPECIFICATIONS FOR MODUS RADIATOR

2 Column= 62mm	3 column= 100mm	4 column= 136mm	5 column= 173mm	6 column= 200mm
----------------	-----------------	-----------------	-----------------	-----------------



Materials	Steel
Connections	½" Flow and return
Test pressure	13 Bar
Testing authority	EN442
Max operation pressure	10 Bar
Max working temperature	110c

These can be cleaned using a soft damp cloth with a non-abrasive cleaning product

INSTALLATION AND FIXINGS

Wall B	rackets	Dir Araft af
Step 1:	Pass screw through the front clamp & spring. Screw into backplate.	
Step 2:	Turn clamp 90 degrees and pass through tubes, turn across tubes and tighten. Fix it into the radiator in the desired position (usually 2/3 sections in from the end).	
Step 3:	Mark the desired position for the wall brackets on the wall + using a suitable drill bit, drill holes and fix the bracket to the wall using the fixings provided.	
Step 4:	Lower the radiator on to the brackets, ensuring they are securely located on the clamp.	
Step 5:	For white radiators – place the spacer between the tube at the bottom of the radiator and adjust the threaded section until the radiator is upright.	
Wall Ti	es	
Step 1:	The way this should be assembled is as follows – remove the backing from the pad and stick it to the inside surface if the clamps.	
Step 2:	Place both clamps around radiator tube and place the L shaped bracket inbetween them	
Step 3:	Mark the L bracket position on the wall and using a suitable drill bit and fixings, fix to the wall.	
Cast Fe	eet / Slip on Feet / Welded Feet	
Step 1:	Place in desired position and place the radiator on top of the foot and fix into position.	
Please N	ote: If you have purchased welded feet, you will need to remove the tie bar p	rior to installation.


<u>www.dqheating.com</u> <u>sales@dqheating.com</u> <u>01842 810833</u>


	Brackets N WHITE*	
Step 1:	Set desired height on floor plate and mount the plastic disc on top of assembly.	
Step 2:	Place radiator on top of assembly and attach the U bar around the section and into the assembly and fix into place.	
Step 3:	Mark the position of the brackets on the floor and ensuring it is safe to do so, using a suitable drill bit and fixings – fix the bracket to the floor.	
Step 4:	Attach the decorative shroud.	

ADDITIONAL INFORMATION

If you are fixing your radiator to a stud wall, you should place the radiator in the desired position and hold up the back plate in position and mark through the fixing holes to a secure position.

Installation of this radiator should only be carried out by a qualified engineer in accordance with local regulations. Failure to do so may invalidate your warranty.





TERMS AND CONDITIONS

You must immediately remove all packaging, inspect the goods and notify us of any damage to the goods within 3 days of delivery. We shall have no obligation to replace or repair damaged goods in the event of failure by the Buyer to comply with this provision. Radiators which are off an unacceptable standard or are damaged must not be installed. If any items is installed it will be treated as being as accepted as received.

Damaged goods being returned will only be collected from your delivery address, unless otherwise agreed in writing. Any other goods, which we accept back, are to be returned by you to our place of business at your expense.

Items will be accepted as a return which have not been installed or damaged after delivery. We do not accept liability for any damages sustained after delivery. Goods should be returned in their original packaging, provided such packaging and goods are undamaged.

We may issue a credit note for goods which we accept as returned.

We may agree to provide you with replacement goods prior to collecting or receiving back the goods to be returned (whether faulty, damaged or otherwise) but only on the condition that: the replacement goods are paid for in full and we reserve the right to re-invoice you in the event that the returned goods are found to be in a worse condition than when they were originally received by you or where such goods have not been received back to us within 3 months of the replacement goods being received by yourselves. A re-stocking charge of 30% will be applied to all non-faulty stock items that wish to be returned. Special order and non-stock products cannot be cancelled. Where cancellation or alteration of orders is accepted by us, you may be required to pay a restocking charge, to cover administrative costs and collection costs (if applicable); such charges to be determined by us. If the goods we deliver are faulty or damaged, we will meet the cost of the return, as long as the fault is reported to us within 3 working days.

The goods will be deemed to have been accepted when they have been delivered and we may not accept claims for any visible defects found after installation.

We accept no liability for any cost incurred relating to the cost of installation.

We shall not be liable for any plumber's costs, decorator's costs, transport costs, late penalties, or any other costs, as a direct or indirect result of (i) any defect in the goods (including but not limited to any manufacturing faults, such as leaks, that become apparent on or after installation) or (ii) late delivery of the goods.

GUARANTEES AND LIABILITIES – we are not the manufacturer of this product we will take all reasonable endeavours to make over to you the benefit of any warranty or guarantee given by the manufacturers. The item must have been fitted in accordance with British and or European standards as well as these fitting instructions.

PLEASE NOTE: That in accordance with Part L1 2006 of the Building Regulations and BS7593:1992 code of practice for the treatment of hot water and central heating systems, we recommend flushing the heating system before installation of new radiators and then adding the correct quantity and type of inhibitor for use with the radiator and system to prevent corrosion. Damage caused to systems not protected by a suitable inhibitor will not be covered by the manufacturer warranty. It is the responsibility of the installer to ensure the correct use and suitability of the fixings provided. No liability for costs or damages arising from failure to do so can be accepted.