

DECLARATION OF PERFORMANCE

Tornado T

Ref: 2026-582



1.	Unique identification code or name:	Tornado T
2.	Intended use:	Heating systems in buildings
3.	Registered name:	Double Quick (Heating) Ltd Units 3 & 4 St Helens House St Helens Way, Thetford, Norfolk IP24 1HG.
4.	Systems of assessment:	System 3
5.	Harmonised standard:	BS EN 442-1:2014
5a.	Testing facility:	Laboratoria Misure Ricerche Termotecniche M.R.T, Via Raffaele Lambruschini, 4 (Zona Bovisa) - 20156, Milano, Italy - No. 1695
5b.	Test Report No:	ENE/MRT.REL.09159

ESSENTIAL CHARACTERISTICS	PERFORMANCE
Reaction to fire	A1
Release of dangerous substances	None
Maximum operating pressure	800
Pressure tightness	No leakage at 1,30 x MOP
Resistance to pressure	No breakage at 1,69 x MOP
Maximum surface temperature	110°C
Rated thermal outputs	Please see table below
Resistance against corrosion	Absence of surface corrosion after 100 h humidity
Resistance against minor impact	Class 0

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, as it has effect in the United Kingdom in respect of Great Britain, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

S C Double
Managing Director



Dated January 2026



Dimensions and Thermal Outputs |

CODE	HEIGHT (mm)	WIDTH (mm)	OUTPUT (WATTS)	
			ΔT 50°C	ΔT 30°C
TOT50/80	750	486	567	292
TOT50/120	1200	486	718	370
TOT50/150	1440	486	865	445
TOT50/180	1720	486	1169	602
TOT60/80	750	586	680	350
TOT60/120	1200	586	860	443
TOT60/150	1420	586	1048	540
TOT60/180	1720	586	1395	718
TOT75/80	750	746	813	419
TOT75/120	1200	746	1096	564
TOT75/150	1440	746	1279	659
TOT75/180	1720	746	1692	871

